

Transmission Loss Allocation Methods in a Deregulated Power System

¹J. Anil Kumar, ²M. Suresh Kumar

¹Research Scholar, ²Assistant Professor, ^{1,2}Department of Electrical Power System, PVKKIT, Anantapur, A.P, India.

Abstract: This paper focuses on the problem of Transmission loss allocation in a power system .It is a centralized issue in today's deregulated market. It is necessary to allocate the real power losses effectively without affecting the market participants due to nonlinear nature of line flows. In this paper a simple novel methodologies are proposed to allocate the losses to the market participants by using simple circuits' laws and loss formulae .These methodologies are tested on standard IEEE 5-Bus system and IEEE 30-Bus system. The simulation results were obtained using MATLAB and compared with the above methodologies

Keywords: Transmission Loss Allocation, Deregulation, Postage Stamp Method, Proportional Sharing Principle method, Bus wise Loss Allocation Method.

I. INTRODUCTION

Deregulation has brought many market configurations and created competition among them in the electricity business. Transaction of electric energy may take many forms like bilateral contracts, power exchange or power pool. Since in deregulated power system generators and loads are connected to the same network, actions by one participant can have significant effect on others making it difficult to investigate the cost .So there is a need for charging energy losses to market participants in a more satisfactory and transparent mechanism. Market participants whether they are generators or consumers want to allocate the loss in more practical way and it is able to reflect each participant's contribution of generation or usage in the network.

In a deregulated power system transmission loss pertains to allocate the cost associated with losses to individual suppliers, generators and contracts of the network. Loss allocation does not affect generation levels or power flows and it is about the distribution of revenues and payments at the network buses among suppliers and consumers and every supplier has to supply the power they want to sell plus the transmission loss corresponding to that transaction.

Transmission loss allocation became contentious issue as it corresponds to a huge amount of money. Transmission loss is a highly nonlinear function of line flows. If linearization techniques are used to allocate flow of a given line to generators and loads, the cross terms associated with quadratic functions doesn't allow assigning losses to generators and consumers in a unique manner. The main problem associated with loss allocation is the fact that transmission loss is a non-separable entity. If any attempt is made to separate it, becomes further complicated by its nonlinear nature.

The challenge facing by a typical power pool and an Independent System Operator (ISO) is how to allocate the transmission loss and what should be the criterion for charging other utilities. Utilities in general look for locational signal, consistency, simplicity, accuracy and predictability in a loss allocation method. It is extremely hard task to accommodate all these considerations in complex phenomenon of transmission loss allocation. So, in a deregulated environment the economic and market related factors are important as technical factors. In this environment not only accurate calculations but fair and equitable allocation of losses to the stake holders are also important. Hence the issue power loss allocation with in the deregulated market still remains an unsolved set back to progress to a fully competitive

electricity market. Based the above problems in this paper proposed a simple novel methodologies to solve the loss allocation problems in a network which illustrated in the subsequent sections.

II. METHODOLOGIES

a. Postage stamp method:

Postage stamp method is the simplest and easy to implement methodology of transmission loss allocation. It is a fixed charge per unit of power transmitted with in a particular zone. It is transparent and is easily understood by all. There is no mathematical rigor involved in this method. In this method 50% of losses are allocated to generators and 50% of losses to the loads. In this method network topology is never taken in to account. Further it will not be beneficiary for two identical loads where one load is locating nearer to the load centre and another load is locating far away from load centre, to allocate the loss with the same amount of cost.

Transmission loss allocation: [1]

Transmission loss allocation for generator is

$$L_{PGi} = \frac{L P_{Gi}}{2 P_G}$$

Transmission loss allocation for generator is

$$L_{PDj} = \frac{L P_{Dj}}{2 P_D} \quad \text{Where, } P_{Gi}, P_{Dj} \text{-- real power generation and load at buses } i \text{ and } j$$


P_G, P_D –Total power generation and load of this system

L_{PGi} –Losses allocated to the generator i

L_{PDj} –Losses allocated to the demand j

L –Total losses of the system

Algorithm for postage stamp method:



b. Proportional sharing principle (Flow tracing method) [4].

Proportional sharing procedures on top of electrical laws requires the assumption of the proportional sharing principle. Using this principle losses are allocated by linear procedure and it is not dependent on slack bus and considers the network flow conditions. To allocate the losses to individual generators and loads, the method depends on simple principle, that the losses associated with certain node in electrical network is proportionally shared by all the paths going

International Journal of Novel Research in Electrical and Mechanical Engineering

Vol. 2, Issue 3, pp: (76-82), Month: September-December 2015, Available at: www.noveltyjournals.com

out from that node thus satisfying Kirchhoff's current law. It should be noted that a systematic applications of this principle originates that all losses are allocated to generators and loads proportionally.

One of the main features of this method is that it is slack-bus independent. Though during the power flow one bus is considered to be slack bus which supplies system loss, while forming transactions this bus also participants. Once transactions are formed, loss is allocated to all transaction pairs, including one involving slack bus. So final result does not depend on the choice of slack bus.

The information required to apply this method is the real power flow and the losses in every line and the power generated or consumed in every bus.

Since there is no unique or ideal procedures exist, the loss allocation should have some desirable properties stated below:

1. To be consistent with the results of power flow.
2. To depend on the amount of energy either produced consumed.
3. To be simple and transparent (important to market participants and public policy makers).
4. To be politically implementable (especially important to regulators and public policy makers).
5. To provide correct marginal signals to the network.

Transmission loss allocation:

Proportional sharing principle method express branch flows as the sum of components supplied from individual generators or to loads.

$$P_{i-j}^{(gross)} = (P_{ij}/P_i) \sum [A_{u(i,k)}] P_{GK} \text{ for } j \in \alpha_i^d \quad (1)$$

α_i^d = set of nodes supplied from node i

P_i = nodal power

K = Buses (generator bus)

P_{GK} = generating power at bus k

P_{ij} = branch power flow (i \in upstream, j \in down stream)

A_u = upstream distribution matrix

$$[A_u]_{ij} = \begin{cases} 1 & \text{for } i=j \\ -|P_{ji}|/P_j & \text{for } j \in \alpha_i^u \\ 0 & \text{otherwise} \end{cases}$$

$$P_{i-j}^{(net)} = (P_{ij}/P_i) \sum [A_{d(i,k)}] P_{DK} \text{ for } j \in \alpha_i^u \quad (2)$$

P_{DK} = load at bus K.

K = buses (load bus).

P_{ij} = branch power flow (j \in upstream, i \in down stream).

α_i^u = set of nodes supplying node i.

A_d = down stream distribution matrix

$$[A_d]_{ij} = \begin{cases} 1 & \text{for } i=j \\ -|P_{ji}|/P_j & \text{for } j \in \alpha_i^d \\ 0 & \text{otherwise} \end{cases}$$

In order to assign 50% of losses to the generation and 50% to the demand, the final generation and demand per bus are computed as,

$$P'_{Gi} = (P_{i-j}^{net} + P_{Gi})/2 \quad (3)$$

$$P'_{Dj} = (P_{i-j}^{(gross)} + P_{Dj})/2 \quad (4)$$

Finally the real power losses allocated to every generator and demand are computed as

$$L'_{Gi} = P_{Gi} - P'_{Gi} \quad (5)$$

$$L'_{Dj} = P'_{Dj} - P_{Dj} \quad (6)$$

c. Bus wise loss allocation:

This method is based on simple circuit laws and does not involve any assumptions. Considering the real power injection and real power loss contribution factors of the buses transmission lines, transmission loss allocation can be done. It does not require any assumptions in the network [2]

Transmission loss allocation: In this method entire data related to the network such as bus voltages, complex line flows, slack bus power generation etc are obtained from the load flow solution. From the load flow solution the complex line flow S_{ij} in terms of the node voltage V_i and line current I_{ij} through the line $i \rightarrow j$ as

$$S_{ij} = V_i I_{ij}^* \quad (1)$$

From the Z based system equations the voltage at node I is given by

$$V_i = \sum_{k=1}^n Z_{ik} I_k \quad (2)$$

The current through the line $i \rightarrow j$ is obtained as

$$I_{ij} = (V_i - V_j) y_{ij} + V_i y_{ij}^{sh} \quad (3)$$

Substituting (2) in (3)

$$I_{ij} = \sum_{k=1}^n [(Z_{ik} - Z_{jk}) y_{ij} + Z_{ik} y_{ij}^{sh}] I_k \quad (4)$$

Substituting the values I_{ij} from (4) in (1)

$$S_{ij} = \sum_{k=1}^n factor1^k_{ij} \quad (5)$$

Thus the complex power flow S_{ij} through the line $i \rightarrow j$ is represented as a function of all bus currents; $k=1, 2, 3, \dots, n$ Factor 1^k_{ij} represents contribution of k^{th} bus to $i \rightarrow j$ line power flow.

Similarly complex line flow

$$S_{ji} = \sum_{k=1}^n factor2^k_{ij} \quad (6)$$

Factor 2^k_{ij} represents contribution of k^{th} bus to $i \rightarrow j$ line complex power flow i.e. counter flow.

Complex line loss in any line is the algebraic sum of active and counter complex line flows. Therefore

$$S_{line\ loss} = S_{ij} + S_{ji} = \sum_{k=1}^n factor^k_{ij} \quad (7)$$

Factor k_{ij} represents the contribution of k^{th} bus to the $i \rightarrow j$ line loss and also the contribution of line $i \rightarrow j$ to the power injection at bus k . The matrix [B] is the real part of $S_{line\ loss}$.

By using [B] matrix real power losses can be allocated in the following manner.

a. Find the sum of the "absolute contribution of all buses to the real power loss of line $i \rightarrow j$ (say " l^{th} line") i.e. cumulative power loss "Cploss(l)" where

$$Cploss(l) = \sum_{k=1}^n B(k, l) \quad (8)$$

b. to find the contribution of i^{th} bus to the real power loss of line $i \rightarrow j$ (l^{th} line) a power loss factor is given by

$$C(k, l) = \frac{B(k, l)}{cploss(l)} * r\ loss(l) \quad (9)$$

c. By summing up all individual real power loss factors $C(k, l)$ of all lines, the total loss allocated to i^{th} bus is defined as $LA(k)$ given by $LA(k) = \sum_{l=1}^{nline} C(k, l)$ (10)

III. CASE STUDY ON IEEE 5 BUS SYSTEM AND IEEE 30 BUS SYSTEMS:

A case study based on IEEE-5 bus system [9] is illustrated to test the performance of the above methodologies. The IEEE- 5 bus system consists of two generators (G_1 and G_2) and four loads (L_2, L_3, L_4, L_5) and is represented by bus power injections, line power flows and line power losses obtained from the base case solution i.e. Newton Raphson method. The total real power loss for 5 bus system is 4.802 MW. By using the above methods loss allocation can be done.

Table-1 shows the results of loss allocation for the three methods of IEEE 5 bus system

Table 1

Bus	Loss allocation in MW (Total loss=4.802)		
	P.S	P.S.P	B.W.L.A
1	1.8355	2.0884	2.131
2	0.8566	0.4318	0.330
3	0.6549	0.6708	0.730
4	0.5821	0.5946	0.650
5	0.8731	1.0167	0.962
Total	4.802	4.802	4.802

Table-2 shows the results of loss allocation for the three methods of IEEE 30-bus system

Table 2

BUS	Loss allocation in MW (Total loss=4.802)		
	P.S	P.S.P	B.W.L.A
1	8.8314	9.3567	9.833
2	1.9665	1.0322	0.544
3	0.0797	0.049	0.075
4	0.2524	0.2035	0.243
5	3.1288	-8.6284	3.056
6	0	0	0
7	0.7573	12.7622	0.736
8	0.9964	0.5869	0.987
9	0	0	0
10	0.1926	0.1869	0.306
11	0.3321	0.3223	0.422
12	0.372	0.3	0.327
13	0.3321	0.2679	0.41
14	0.2059	0.1968	0.206
15	0.2724	0.2723	0.27
16	0.1162	0.108	0.106
17	0.2989	0.2993	0.276
18	0.1063	0.1179	0.109
19	0.3155	-3.8748	0.308
20	0.0731	4.319	0.075
21	0.5812	0.6423	0.547
22	0	0	0
23	0.1063	0.1166	0.103
24	0.289	-1.4931	0.304
25	0	0	0
26	0.1162	-1.4823	0.162
27	0	0	0
28	0	0	0
29	0.0797	0.8176	0.116
30	0.3521	3.6936	0.624
Total	20.15	20.15	20.15

From the results of IEEE 5 bus system, it can be

Observed That:

P.S.method does not consider the network. It allocates the losses to the generators and loads marginally and it is independent of transmission distance. Here it allocates the losses of 1.8355MW the bus -1 with its more contribution of 129.802MW power flow to the other loads and it allocates losses of 0.8566 MW to the bus-2, but its contribution of power flow is only 40 MW apart from its own load.

In P.S.P method taking the network in to consideration, allocation can be done. It allocates the losses of 2.0884MW to bus-1 as it contributes the 129.802MW to other loads and it allocates the 0.4318 MW to bus -2 with its contribution of 40 MW to the other loads.

In B.W. method allocation can be done directly by using circuit laws. It allocates the losses of 2.131MW to the bus-1 with its contribution of power flow to the other loads is 129.802MW.and it allocates the losses of 0.330MW to the bus-2 with its contribution of power flow to other loads is 40MW.so from this analysis

In P.S method the participant with more contribution will get more benefited compared to less contribution of the participants.

But with P.S.P method though network is taken in to Consideration, customers are not reasonably benefited compared to the Bus wise loss allocation method. So bus wise loss allocation method allocates losses more accurately compared to the other two methods.

From the results of IEEE 30 bus system it can be observed that all the methods allot zero loss to the transfer bus which has zero injection power. In PSP method negative losses occur when no of buses increases, but in BWLA method negative losses never occur though no of buses increases as shown in table 1 and table 2 respectively.

IV. CONCLUSION

From the above three methodologies the following conclusions can be drawn

P.S method though simple and transparent to implement it does not take the network in to consideration and allocates the fixed real power loss to the participants irrespective of distance between the generators and loads.

Proportional sharing method takes the network in to consideration and allocates the real power losses proportionally to all the transactions. But here assumptions are made that the line inflows are equal to the line out flows. This method does not depend up on the choice of the slack bus.

Bus wise loss allocation method overcomes the above disadvantages and allocates the real power losses directly by using simple circuit laws. This method gives accurate results compared to the other two methods.

Future scope: Here in this paper only real power losses are considered for loss allocation. The above three methods can be extended to allocate the reactive power losses for better voltage stability and pricing can also be done which is a major issue in today's competitive market.

REFERENCES

- [1] A. Conejo, J. Arroyo, N. Alguacil, and Guijarro, "transmission loss allocation comparison of different practical algorithms", *IEEE transactions on power systems*, vol.17, no.3, pp.571-576, August 2002
- [2] S.Abdelkader, "A new method for transmission loss allocation considering the circulating currents between generators", *IEEE power systems conference 12th international Middle- East*, pp.282-286, March 2008.
- [3] F.Galiana, A.Conejo, and I.Kockar, " Incremental transmission loss allocation under pool dispatch", *IEEE transactions on power systems*, vol.17,no.1,pp 26-32, February 2002.
- [4] Janusz Bialek, "Topological generation and Load Distribution factors for supplement charge allocation in transmission open access", *IEEE transactions on power systems*, vol.12, no.3, August 1997.

International Journal of Novel Research in Electrical and Mechanical EngineeringVol. 2, Issue 3, pp: (76-82), Month: September-December 2015, Available at: www.noveltyjournals.com

- [5] Juan Carlos Mateus and Pablo Cuervo Franco, "transmission loss allocation through equivalent Bilateral Exchanges and Economical analysis", *IEEE transactions on power systems*, vol.20, no.4, pp.1799-1807, November 2005.
- [6] A.G. Exposito, J.M. R. Santos, T.G. garcia et al, "Fair allocation of transmission power losses", *IEEE transactions on power systems*, vol.15, no.1, pp,184-188, Feb.2001.
- [7] G. Gross and S. Tao, "A physical-flow based approach to allocating transmission losses in transaction frame work", *IEEE transactions on power systems*, vol.15, pp.631-637, May 2000.
- [8] "Power system restructuring and deregulation- trading, performance and information technology", Edited by Loi Lei Lai, John Wiley & sons Ltd, Chichester.
- [9] "Computer methods in power system analysis" by Glenn W. Stagg and Ahmed H. El-Ablad.
- [10] Mala De, Nalin B. Dev choudhury, and swapan, k.Goswami, "transaction based power flow solution and transmission loss allocation using Neural Network", *IEEE transactions on power systems*.
- [11] F. Gubina, D. Grgic, and I. Banic, "A method for determining the generators share in a consumer load", *IEEE Trans. Power Syst.*, vol. 15, pp.1376-1381, Nov. 2000."